

Ventilation system ComfoAir Luxe

User document

zehnder

always
around you

Heating

Cooling

Fresh Air

Clean Air



ComfoAir 160



ComfoAir 200



ComfoAir 350



ComfoAir 450
ComfoAir 550

Foreword



Read this document carefully before use.

This document provides all the information required for safe and optimal operation and maintenance of the ComfoAir 160, 200, 350 or 550. In this document it will be referred to as “the unit”. The unit is subject to continuous development and improvement. As a result, the unit may slightly differ from the descriptions.

The following pictograms are used in this document:



Point of attention.



Risk of:

- damage to the device;
- performance of the device is compromised if instructions are not observed carefully.



Risk of personal injury for the user.



Maintenance



Questions

Please contact the supplier if you have any questions or would like to order a new document or new filters. The contact details of the main supplier can be found on the rear flap of this document.

The following information can be found in this document:

Information	Chapter
General information about the ventilation system.	1
Safety instructions which must be followed.	1
Operating devices available for the unit.	2
A summary of all the different parameters (P-menus).	2
Warranty and liability conditions.	3
What to do with the unit at the end of its life.	3
EEC declaration of conformity.	3
How to replace the filters of the unit.	4
How to clean the valves of the ventilation system.	4
When the installer or maintenance mechanic must come by for the maintenance of the unit.	4
What to do in event of an malfunction.	5

All rights reserved.

This documentation has been compiled with the utmost care. The publisher cannot be held liable for any damage caused as a result of missing or incorrect information in this document. In case of disputes the English version of these instructions will be binding.

Table of Contents

Foreword	2
1 Introduction and safety	5
2 Operation	6
2.1 Available operating devices	6
2.2 P menus for the user	7
3 CE certification and warranty	8
4 Maintenance 	9
4.1 Cleaning or replacing the filters 	9
4.1.1 Replacing the internal filters 	10
4.1.2 Cleaning the internal filters 	11
4.1.3 Replacing or cleaning the external filter 	11
4.2 Cleaning the valve 	11
4.3 Condensation drain 	11
4.4 Maintenance by the installer or maintenance mechanic 	11
5 Malfunctions	11
I Commissioning & Inspection Record	12
II Maintenance log	13

1 Introduction and safety

The unit is a balanced ventilation system with heat recovery in order to create energy-efficient ventilation in houses. Balanced ventilation means that pollutants from the kitchen, the bathroom, the toilet(s) and possibly the storage room are extracted, while the same amount of fresh air is blown into the living room and bedrooms. Gaps under or near the doors ensure a good through-flow in the dwelling.

! Ensure that the gaps under or near the door are never obstructed. For example by furniture, draught excluders or deep-pile carpet.


A balanced ventilation system consists of:

- The unit (A);
- Duct system for the supply of outdoor air (B);
- Duct system for the exhaust of indoor air (C);
- Supply valves in the living room and bedrooms (D);
- Exhaust valves in the kitchen, bathroom, the toilet and (if present) the storage room (E).

Safety instructions

Always follow the safety regulations, warnings, comments and instructions given in this document. Personal injury or damage to the unit can arise from non-compliance with the safety regulations, warnings, comments and instructions in this document.

- It is recommended to take out a maintenance contract so that the device is checked on a regular basis. The supplier can provide a list of registered installers nearby;
- The unit may only be installed, connected, rendered operational and maintained by an appropriately approved installer, unless otherwise indicated in this document;
- Store the document for the entire working life of the unit;
- Instructions with regard to cleaning or replacing the filters must be carefully observed;
- When carrying out any work on the unit, make sure the power is disconnected and cannot be inadvertently reconnected;
- The unit cannot be opened without using tools.



2 Operation

How to use and read the operating devices of the unit is mentioned in the document of the operating device.

2.1 Available operating devices

One or more of the following operating devices can be present to operate the unit:

Appearance	Name	Functions
	Bathroom switch	Activating the overrun timer.
	RFZ	Set the desired ventilation level: <ul style="list-style-type: none"> ■ 1 = Low; ■ 2 = Normal; ■ 3 = High; ■ ☺ = Overrun timer. Indicating a malfunction or filter alert.
	ComfoSense	Indicating and setting the desired ventilation level: <ul style="list-style-type: none"> ■ ☺ = Absent ■ ☺ = Low; ■ ☺ = Normal; ■ ☺ = High; ■ PARTY TIMER = Overrun timer; ■ AUTO = Preset programme. Indicating a malfunction or filter alert; Indicating if the bypass, pre heater, ComfoFond-L, ComfoHood**, preset programme, analogue programme or overrun timer is activated; Turning the supply and/or exhaust fan on and off; Turning the ComfoHood** on and off; Indicating and setting the comfort temperature; Setting the P-menus; Resetting the malfunctions and filter alert; Setting a preset ventilation programme; Setting and showing date and time.
	CC Luxe**	Indicating and setting the desired ventilation level: <ul style="list-style-type: none"> ■ A = Absent ■ 1 = Low; ■ 2 = Normal; ■ 3 = High; ■ ☺ 3 = Overrun timer; ■ AUTO = Preset programme. Indicating a malfunction or filter alert; Indicating if the bypass, pre heater, ComfoFond-L, ComfoHood**, preset programme, analogue programme or overrun timer is activated; Indicating outside and inside temperatures; Turning the supply and/or exhaust fan on and off; Turning the ComfoHood** on and off; Indicating and setting the comfort temperature; Setting the P-menus; Resetting the malfunctions and filter alert; Setting a preset ventilation programme; Setting a preset comfort temperature programme; Setting and showing date and time; Setting languages and screen configuration.
	CO ₂ sensor	Indicating and setting the desired ventilation level: <ul style="list-style-type: none"> ■ I = Low; ■ II = Normal; ■ III = High; ■ Auto = Automatic (according to measured CO₂ level); Indicating the CO ₂ level.

** Only available on the ComfoAir350Luxe, ComfoAir450Luxe and ComfoAir550Luxe.

2.2 P menus for the user

A summary of all the accessible P-menus is given below.

Menu P1 > Status of time programmes

Submenu	Description	Status
		Activated
P10**	Is menu P20 currently active?	Yes (1) / No (0)
P11	Is menu P21 currently active?	Yes (1) / No (0)
P12	Is menu P22 currently active?	Yes (1) / No (0)
P13	Is menu P23 currently active?	Yes (1) / No (0)
P14	Is menu P24 currently active?	Yes (1) / No (0)
P15	Is menu P25 currently active?	Yes (1) / No (0)
P16	Is menu P26 currently active?	Yes (1) / No (0)
P19**	Is menu P29 currently active?	Yes (1) / No (0)

Menu P9 > Status of additional programmes

Submenu	Description	Status
		Activated
P90	Open fire programme active?	Yes (1) / No (0)
P91	Bypass open?	Yes (1) / No (0)
P92**	ComfoFond-L** valve open?	Yes (1) / No (0)
P93**	Post heater on?	Yes (1) / No (0)
P94	Analogue input (0-10V) active?	Yes (1) / No (0)
P95	Frost protection or pre heater active?	Yes (1) / No (0)
P96**	ComfoHood** on?	Yes (1) / No (0)
P99	Enthalpy programme active?	Yes (1) / No (0)

Menu P2 > Setting time delays

Submenu	Description	Time delay values		
		Minimum	Maximum	General reset
P20**  Only applies to systems fitted with a ComfoHood**.	Overrun timer for the ComfoHood** programme. ■ 'x' minutes after operating the ComfoHood** switch the unit reverts back to the normal setting.	0 Min.	180 Min.	0 Min.
P21	Delay timer for the bathroom switch (to switch to high position). ■ 'x' minutes after operating the bathroom switch, the unit switches to the high setting.	0 Min.	15 Min.	0 Min.
P22	Overrun timer for the bathroom switch (to switch to normal position). ■ 'x' minutes after operating the bathroom switch, the unit switches back to the normal setting.	0 Min.	120 Min.	30 Min.
P23	n/a	0 Min.	120 Min.	0 Min.
P24	Filter warning ■ 'x' weeks after cleaning the filters the "filter dirty" alert will reappear.	10 weeks	26 weeks	16 weeks
P25  Only applies to systems fitted with an RFZ switch.	Overrun timer for ventilation setting 3 (using ☺). ■ After pressing ☺ briefly (< 2 sec.), the unit will switch to the high setting for 'x' minutes and then automatically returns to the normal setting. If any switch is operated during this lagging time the unit will instantly revert to the ventilation position as set at that time.	1 Min.	20 Min.	10 Min.
P26  Only applies to systems fitted with an RFZ switch.	Overrun timer for ventilation setting 3 (using ☺). ■ After pressing ☺ continuously (> 2 sec.), the unit will switch to the high setting for 'x' minutes and then automatically returns to the normal setting. If any switch is operated during this lagging time the unit will instantly revert to the ventilation position as set at that time.	1 Min.	120 Min.	30 Min.
P27  Only applies to systems fitted with a ComfoSense or CC Luxe**.	Time for the boost setting. ■ After pressing  3 on the CC Luxe** or after turning on the PARTY TIMER on the ComfoSense, the unit will switch to the high setting for 'x' minutes and then automatically returns to the normal setting. If any switch is operated during this lagging time the unit will instantly revert to the ventilation position as set at that time.	0 Min.	120 Min.	30 Min.
P29**  Only applies to systems fitted with a ComfoHood**.	Setting the ComfoHood** ventilation levels. ■ When the ComfoHood** is switched on the ComfoHood** ventilation settings can be set x-% higher than the corresponding 'normal' ventilation levels.	1%	99%	10%

** Only available on the ComfoAir350Luxe and ComfoAir550Luxe.

3 CE certification and warranty

Warranty conditions

The unit is covered by a manufacturer's warranty for a period of 24 months after fitting up to a maximum of 30 months after the date of manufacture. Warranty claims may only be submitted for material faults and/or construction faults arising during the warranty period. In the case of a warranty claim, the unit must not be dismantled without written permission from the manufacturer. Spare parts are only covered by the warranty, if they were supplied by the manufacturer and have been installed by an approved installer.

The warranty becomes invalid if:

- The guarantee period has elapsed;
- The device is used without filters;
- Parts are used that have not been supplied by the manufacturer;
- Non-authorized changes or modifications have been made to the unit.
- Installation has not been carried out according to the applicable regulations;
- The defects are due to incorrect connection, inexperienced use, or contamination of the system;

On-site (dis)assembly costs are not covered by the terms of the warranty. This also applies to normal wear and tear. Zehnder retains the right to change the construction and/or configuration of its products at any time without being obliged to alter previously delivered products.

CE certification

Zehnder Group Nederland B.V.
Lingenstraat 2 • 8028 PM Zwolle-NL
T +31 (0)38 4296911 • F +31 (0)38 4225694
Company register Zwolle 05022293

Machine description

Complies with the following directives

EEC declaration of conformity

Heat recovery units: ComfoAir 160, 200, 350, 550 series

Machinery Directive	(2006/42/EEC)
Low Voltage Directive	(2006/95/EEC)
EMC Directive	(2004/108/EEC)

Zwolle, 05.01.10

Zehnder Group Nederland B.V.



E. van Heuveln,
Managing Director

Liability

The unit has been designed and manufactured for use in balanced ventilation systems incorporating Zehnder heat recovery systems. Any other application is seen as inappropriate use and can result in damage to the unit or personal injury, for which the manufacturer cannot be held liable. The manufacturer is not liable for any damage originating from:

- Non-compliance with the safety, operating and maintenance instructions in this document;
- The use of components not supplied or recommended by the manufacturer.
Responsibility for the use of such components lies entirely with the installer;
- Normal wear and tear.

End of useful life

Consult with the supplier about what should be done with the unit at the end of its useful life. If the unit cannot be returned to the supplier, avoid disposing of it with the domestic waste, and ask your local council about the options for recycling the components or processing the materials in an environmentally friendly manner.

Furthermore, do not dispose of batteries from the wireless (RF) switches with the normal waste, but bring them to the specially designated disposal locations.

4 Maintenance

 **Failure to carry out (periodic) maintenance on the unit ultimately compromises the performance of the ventilation system.**

The unit should be inspected and cleaned every 2 years by a specialist. To ensure a hassle free lifespan for your unit, we recommend you take out a service agreement with an expert company.

 **Ensure the unit has been disconnected from mains power before carrying out any maintenance work.**

The power to the unit should not be disconnected unless the unit is to be taken out of service due to a serious malfunction, or for filter replacement or any other compelling reasons.

 **If the power to the unit is disconnected, mechanical ventilation of the dwelling will cease. This can lead to a build-up of moisture and results in problems with mould.**

4.1 Cleaning or replacing the filters

 **Replace the filters (at least) every six months and clean the filters every 2 or 3 months.**




When indicated on the ComfoSense or CC Luxe** you must clean or replace the filters.

The installer of the unit can provide the necessary new filters.

Unit type	Filter type	Article number
ComfoAir 160	2x G4	400100023
	1x F7 / 1x G4	400100024
ComfoAir 200	1x F7 / 1x G4	400100013
	2x G4	400100014
	2x F7	400100017
ComfoAir 350	2x G4	006040200
	1x F7 / 1x G4	006040250
ComfoAir 550	2x G4	006040200
	1x F7 / 1x G4	006040250

** Only available on the ComfoAir350Luxe and ComfoAir550Luxe.

4.1.1 Replacing the internal filters

Action		Explanation
1		<p>Reset the filter error as mentioned in the manual of the ComfoSense or CC Luxe**.</p>
2		<p>Disconnect the power from the unit.</p>
3	 <p>ComfoAir 160</p> <p>ComfoAir 200</p>	<p>Remove the handles (A) from the unit.</p>
3	 <p>ComfoAir 350</p> <p>ComfoAir 550</p>	<p>Remove the handles (A) from the unit.</p>
4	 <p>ComfoAir 160/200</p> <p>ComfoAir 350/550</p>	<p>Remove the dirty filters (B) from the unit.</p>
5		<p>Install the clean filter back into the unit and reconnect the power.</p> <p> When using the unit for the first time, it is recommended to replace the filters (and clean the valves) first. During the construction phase the ventilation system could have become dirty with building dust.</p>

** Only available on the ComfoAir350Luxe and ComfoAir550Luxe.

4.1.2 Cleaning the internal filters

Vacuum the filters (B) with a vacuum cleaner instead of replacing them with new filters.



When using the unit for the first time, it is recommended to clean the filters (and valves) first. During the construction phase the ventilation system could have become dirty with building dust.

4.1.3 Replacing or cleaning the external filter

If so indicated on the ComfoSense or CC Luxe** you must clean or replace the filter as is mentioned in the external filter document.

4.2 Cleaning the valve

Clean the valves (at least) twice a year.

1. Mark the setting of the valve;
2. Remove the valve from the wall or ceiling;
3. Clean the valve in a solution of soap and warm water;
4. Rinse the valve thoroughly and wipe dry;
5. Place the valve back WITH EXACTLY THE SAME SETTING (and IN THE SAME HOLE);
6. Repeat this procedure for the other valves.



Some valves have a filter behind it. If a filter is present clean this in the same way as the valve.

About the valve settings

The ventilation air is supplied and discharged by means of valves. Gaps under or near doors in the dwelling ensure that the air flows in the right direction. In order to ensure that the correct ventilation volumes are maintained in the rooms, the following must be observed:

- Do not seal the gaps under or near the doors. For example by furniture, draught excluders or deep-pile carpet. The gap should be at least 2cm;
- Do not change the settings of the valves;
- Do not replace the valves with one another.

The installer will have set all the valves to ensure the optimum performance of the ventilation system. Therefore, do not change the setting of the valves.

4.3 Condensation drain

Ensure that the water seal (u-bend) connected to the domestic waste-water system is always full of water.

4.4 Maintenance by the installer or maintenance mechanic

Not all necessary maintenance can be done by the user.



Once every 2 years the installer or a maintenance mechanic should come by for the maintenance inside the balanced ventilation system.

Some installers offer a full maintenance contract package where the user maintenance can also be integrated.

5 Malfunctions

In the event of a malfunction, the corresponding malfunction code will be displayed on the ComfoSense or CC Luxe** of the unit.

In event of a filter malfunction the filter must be cleaned or replaced as described in the Maintenance chapter.

In the event of all other malfunction:

	Action	Explanation
1		Note down the malfunction code that appears on the ComfoSense or CC Luxe** of the unit.
2		Note down the unit type. This is given on the identification plate on the unit near the power supply.
3		Contact the installer or maintenance mechanic and give him the noted information.

The system should not be disconnected from the power supply, unless the unit must be taken out of service due to a serious malfunction, or for filter cleaning/replacement or any other compelling reasons.



If the unit is disconnected from the power supply, mechanical ventilation of the dwelling will cease. This can lead to a build-up of moisture and results in problems with mould.



If the unit is installed in an area with a higher average humidity (such as bathroom or toilet) the probability of condensation on the outside of the unit is high. This is similar to condensation on a window and no action is needed.

** Only available on the ComfoAir350Luxe and ComfoAir550Luxe.

I Installation/test report

Date		Address	
Work instruction		Town/city	
Commissioning party		Project type	
Installed by		Residence type	
Gemeten door		Unit type	

Return

Room	Position	Required [m ³ /h]	Tested [m ³ /h]	Type valve	Settings valve	Settings unit	
Kitchen						P30	
Bathroom						P31	
Toilet						P32	
...						P33	
...							
...							

Total:			
--------	--	--	--

Supply

Room	Position	Required [m ³ /h]	Tested [m ³ /h]	Type valve	Settings valve	Settings unit	
Living room						P34	
Bedroom 1						P35	
Bedroom 2						P36	
Bedroom 3						P37	
...							
...							
...							

Total:			
--------	--	--	--

Pressure

Measured	Supply [Pa]	Return [Pa]
Press pressure		
Suction pressure		

Total:		
--------	--	--



Zehnder Group Nederland B.V.
Lingenstraat 2 • 8028 PM • Postbus 621 • 8000 AP Zwolle
T +31 38 429 69 11 • F +31 38 422 56 94
info@zehnder-jestorkair.nl • www.zehnder-jestorkair.nl

